

Rui Da Shu

From: Guy V. Zito <gzito@npcc.org>
Sent: Tuesday, October 14, 2014 10:44 AM
To: rsballot
Cc: rscmembers
Subject: NERC Ballot Project 2010-05.2 – Special Protection Systems

NPCC Entities and Members of the NERC Registered Ballot Body,

The NPCC Regional Standards Committee has reviewed and commented on the subject standard. The additional ballot period closes at 8pm, today October 14th, 2014. There have been a couple of issues identified that support recommendation of a vote to **“Reject”** the standard in this additional ballot. These issues will be included in the NPCC comments to the Standard Drafting Team and the comment form itself will be posted to the NPCC website. The issues involved implementation of the new definition in the PRC-024 standard and also the need to exclude some of the HVDC protection systems from the RAS definition. Further details on the NPCC comments will be posted today at:

<https://www.npcc.org/Standards/Regional%20Standards%20Comments/Forms/Public%20List.aspx>

If you have questions please contact me.

Guy V. Zito
Assistant Vice President-Standards
Northeast Power Coordinating Council Inc.
1040 Avenue of the Americas, 10th Floor
New York, NY 10018
212-840-1070
212-302-2782 fax