

## Rui Da Shu

---

**From:** Guy V. Zito <gzito@npcc.org>  
**Sent:** Friday, March 13, 2015 2:15 PM  
**To:** rsballot  
**Cc:** rscmembers  
**Subject:** NERC Ballot-Project 2010-14.1 Phase 1 of Balancing Authority Reliability-based Controls: Reserves - BAL-002-2  
**Attachments:** LPv1--3-13-15--Project 2010-14 1 BAL-002-2 Comment Form - 2015 01 26 (1).docx

NPCC Members of the NERC Registered Ballot Body,

The Regional Standards Committee has reviewed the subject standard and conducted a call with members of the Standards Drafting Team for the subject standard currently posted for formal comment and an "Additional Ballot" through **8pm March 16<sup>th</sup>, 2015**. I have not heard from all the NPCC RSC Members so total consensus has not been formally reached. I am attaching an initial draft of the comment form Lee Pedowicz-NPCC staff is working towards finalizing for the Monday deadline for submission. Based on the comments, **NPCC as the Regional Entity will be voting Negative** and will be attending the next SDT meeting to discuss the issues further with the team. There are compliance issues, DC tie line treatment issues in the Area Control Equation, vagueness with terms such as "sudden", an issue with DCS for a BA wheeling power through it, etc. Suggestions have made to pursue Regional Variances and "grandfathering" to address our issues however there may be other Eastern Interconnection Regions who also may have issues. RSC will be reviewing the comments submitted for this posting and discussing ways forward at their next meeting in April, 2015.

If there are any questions please contact me.

Thank you,

Guy V. Zito  
Assistant Vice President Standards  
Northeast Power Coordinating Council, Inc.  
1040 Avenue of the Americas, 10<sup>th</sup> Floor  
New York, NY 10018  
212-840-1070  
212-302-2782 Fax  
[gzito@npcc.org](mailto:gzito@npcc.org)

