

From: [Ruida Shu](#)
To: [rsballot](#)
Cc: [rscmembers](#)
Subject: NERC Project 2021-04 Modifications to PRC-002 Initial Ballot Recommendation
Date: Friday, July 22, 2022 3:06:22 PM

NPCC Members and Entities of the NERC Registered Ballot Body:

Currently, there is a 45-day comment period open through 8 p.m. EST, Monday, July 25, 2022, for the subject project. The project proposes revisions to the following standards and has an associated Implementation Plan.

-PRC-002-4 – Disturbance Monitoring and Reporting Requirement -- Ballot Recommendation:

The purpose of PRC-002 is to have adequate data available to facilitate analysis of BES disturbances. Requirements R1 and R5 specify where Sequence of Events Recording (SER) and Fault Recording (FR) data, and where Dynamic Disturbance recording (DDR) data, respectively, are required in the Bulk Electric System (BES).

The goal of the project is to clarify the necessary notifications in Requirement R1, Part 1.2 relative to FR data, and clearly identify the BES Element owners that need to have FR data for transformers and transmission lines with the associated identified bus.

In recognition of Regional Standard Committee (RSC) concerns, NPCC as the Regional Entity will be casting an ‘Abstention’ on the posted materials. The RSC will also be submitting comments addressing these concerns.

Thanks,

Ruida Shu

Manager, Reliability Standards



Northeast Power Coordinating Council, Inc.

1040 Avenue of the Americas - 10th Floor
New York, New York 10018

O: (917) 934-7976 • **C:** (917) 232-5140

rshu@npcc.org • www.npcc.org